



DETAILS OF 'A'

KIT SELECTION TABLE	
KIT NO.	CABLE SIZE IN sqmm.
MHI-1	25-35
MHI-2	50-95
MHI-3	120-185
MHI-4	240-300
MHI-5	400-500

15	INSTRUCTION SHEET
14	SILICON GREASE
13	CLEANING LIQUID
12	AL. OXIDE CLOTH
11	NYLON STRING
10	COPPER BINDING WIRE
9	EARTH CONTINUITY CONNECTION
8	AL. CRIMPING LUG
7	MONOPLAST TAPE
6	RED MASTIC
5	STRESS GRADING MASTIC
4	STRESS CONTROL TUBE
3	LUG SEAL
2	ANTI TRACKING TUBE
1	BREAKOUT
Sr.No.	KIT CONTENTS

NOTE:-DO NOT SCALE. IF IN DOUBT, PLEASE ASK. ALL DIMENSIONS ARE IN mm

<b>3M</b> 3M ELECTRO & COMMUNICATION INDIA PVT. LTD PIMPRI, PUNE-411018.		MATERIAL AS STATED			
		SUPERSEDES OLD ISSUE DTD. ---			
TITLE : <b>M-SEAL HEAT SHRINK INDOOR TERMINATION ON 6.6kV(UE)/11kV(E), 3 CORE XLPE CABLE</b>		BY	SIGN	DATE	DATE OF RELEASE
PROJECTION FIRST/THIRD ANGLE. SCALE:- NTS		DRN.	Y.K.D.	04.12.06	---
		CHD.	R.S.	05.12.06	---
		APPD.	P.I.	06.12.06	---
SHEET NO. 1 OF 1		ISSUE NO. 1	REV. NO. 0	DRAWING NO. H111E301	